

The manufacturer
may use the marks:



Certification Report:

ABB 800M Q2003111 CSA
1.0.0 ISASecure Device
Assessment Report V1R1

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:

Product certificate remains valid under conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number ABB 2003111 C001 issued to ABB AB
- AC 800M / AC 800M HI Controller V6.1.x remains under security management practices thereby certified

Revision 1.0 May 20, 2021



ISASecure Chartered Laboratory:

exida
80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001
AClass Cert No: AT-1531



T-XXX V1R0

Certificate / Certificat

Zertifikat / 合格証

ABB 2003111 C001

exida hereby confirms that the

AC 800M / AC 800M HI Controller

ABB AB

Malmö/Västerås, Sweden

Has been assessed per the relevant requirements of:

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical security requirements for IACS components

ISASecure Component Security Assurance (CSA) 1.0.0 Capability Security Level 1 requirements for embedded devices, referencing errata CSA-102 v1.0

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject under Assessment	Date	Current releases at time of assessment
ISASecure® CSA evaluation	AC 800M Controller Models PM857(HI), PM858(PA), PM862(PA), PM863(HI), PM866A(PA), PM867(HI) V6.1.x (x greater than 0)	May 20, 2021	6.1.1-0



David A. Johnson

Evaluating Assessor

David Lybath

Certifying Assessor