

The manufacturer
may use the marks:



Certification Report:

ABB 18-08-112 R002 V1R1

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:

Product certificate remains valid under conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number ABB 1808112 C001 issued to ABB AB
- AC 800M Controller Version 6.0.0-x remains under security management practices thereby certified

Revision 1.1 April 15, 2020



ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#1004

ISASecure Chartered Laboratory:

exida

80 North Main St.
Sellersville, PA 18960

License: ISCI-CL0001

ACLASS Cert No: AT-1531



T-158 V1R0

Certificate / Certificat

Zertifikat / 合格証

ABB 1808112 C002

exida hereby confirms that the

AC 800M Controller

ABB AB

Malmö/Västerås, Sweden

Has been assessed per the relevant requirements of:

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical security requirements for IACS components

ISASecure Embedded Device Security Assurance 3.0.0 Level 1 referencing errata EDSA-102 v5.0

Meeting requirements for: Capability Security Level 1

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject under Assessment	Date	Current releases at time of assessment
ISASecure® EDSA evaluation	AC 800M Controller Model PM866	Mar 31, 2020	6.0.0-3



Authorized Representative