

The manufacturer
may use the marks:



Certification Report:

HON 2105012 R001 V1R1

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:

Product certificate remains valid under the following conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number HON 1906104 C001 issued to Honeywell Process Solutions
- Experion CN100 Controller Version R520 remains under security management practices thereby certified

Revision 2.0 June 22, 2022



ISASecure Chartered Laboratory:

exida
80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001
AClass Cert No: AT-1531



T-171 V1R3

Certificate / Certificat Zertifikat / 合格証

HON 2105012 C001

exida hereby confirms that the

Experion CN100 Controller Honeywell Process Solutions Fort Washington, PA, USA

Conforms to 62443 requirements listed and to requirements shown:

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2018 Technical security requirements for IACS components

Meeting Requirements for:

ISASecure Component Security Assurance (CSA) 1.0.0 Capability Security Level 2 requirements for embedded devices, referencing errata CSA-102 v1.9

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject under Assessment	Date	Current releases at time of assessment
ISASecure® CSA evaluation	Experion CN100 Controller	June 22, 2022	R520



David A. Johnson, [Signature], [Signature]

Evaluating Assessors

Bill Thonson

Certifying Assessor