

Certificate



968/EDSA 1005.01/20



Product tested	Safety-Related Programmable Electronic System (2oo3 with diagnostics (2oo3D) and 3-2-1-0 or 3-2-0 configurable mode of operation)	Certificate holder	Schneider Electric Systems USA, Inc. 26521 Rancho Parkway South Lake Forest, CA 92630 USA
Type designation	Tricon CX System V11.5 Tricon Communication Module - TCM 4355X Firmware Revision 675 Build 695		
Scope and result	ISA Secure Embedded Device Security Assurance (EDSA) 3.0.0 (incorporating EDSA-102, Errata v5.1) The system complies with the requirements of ISA Secure EDSA 3.0.0 - Level 1.		
Specific requirements	For the use of the system the safety and security considerations as documented in the product and user guides must be considered.		

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1104.14/20 dated 2020-04-06.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2020-04-06

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. Thomas Steffens