

The manufacturer
may use the marks:



ISASecure®
CERTIFIED COMPONENT



Certification Report:

ENV 2302059 R004 V1R2

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions while using the secure protocols as documented in the security guidelines and in the product certification report.

Validity:

Product certificate remains valid under the following conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number ISASL 117990 0010 Rev. 00 issued to **Shanghai Univers Co., Ltd.**
- EnOST™ Edge Logger DTU Version 2.x remains under security management practices thereby certified

Revision 1.3 July 13, 2026



ISASecure Chartered Laboratory:

exida

80 North Main St.

Sellersville, PA 18960

License: ISCI-CL0001

ACLASS Cert No: AT-1531



T-171 V1R8

Certificate / Certificat Zertifikat / 合格証

ENV 2302059 C004

exida hereby confirms that the

EnOST™ Edge Logger DTU

Shanghai Univers Co., Ltd.

(上海远景科创智能科技有限公司)

No.15, Lane 55, Chuanhe Road,

Shanghai Pilot Free Trade Zone

China

Conforms to 62443 requirements listed and to requirements shown:

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical security requirements for IACS components

Meeting Requirements for:

ISASecure Component Security Assurance (CSA) 1.0.0 Capability Security Level 1 requirements for embedded devices, referencing errata CSA-102 v2.5

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject under Assessment	Date	Current releases at time of assessment
ISASecure® CSA evaluation	EnOST™ Edge Logger DTU	March 26, 2025	2.4



Jack Gao

Evaluating Assessor

Bill Thonson

Certifying Assessor