

The manufacturer
may use the marks:



ISASecure®
CERTIFIED COMPONENT



Certification Report:

JCI 1909037 R001 V1R0

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:

Product certificate remains valid under the following conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number JCI 1909037 C002 issued to Johnson Controls International
- The Component described in the table to the right remains under security management practices thereby certified

Revision 1.0 December 30th 2025



ISASecure Chartered Laboratory:

exida
80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001
AClass Cert No: AT-1531



T-171 V1R8

Certificate / Certificat

Zertifikat / 合格証

JCI 1907144 C005

exida hereby confirms that the

YVAA/YVFA Style A Air-Cooled Screw Chillers

Johnson Controls International PLC Cork, Ireland

Conforms to 62443 requirements listed and to requirements shown:

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical security requirements for IACS components

Meeting Requirements for:

ISASecure Component Security Assurance (CSA) 1.0.0 Capability Security Level 1 requirements for embedded devices, referencing errata CSA-102 v1.9

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject Model	Subject Type	Current releases at time of assessment
ISASecure® CSA evaluation	YVAA/YVFA Style A GUI	Screw Chiller Controller	V05, V06, V09, and V10



David A. Johnson *Bill Thonson*

Evaluating Assessor

David G. Smith

Certifying Assessor