The manufacturer may use the marks:

ISASecure® CERTIFIED COMPONENT

exida CERTIFIED IEC 62443 SL-C 2

Certification Report:
HON 2603046 R001 V1R0

Application Restrictions:
The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:
Product certificate remains valid under the following conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number HON 2103121 C001 issued to Honeywell Building Technologies
- Trend IQ5 System Controller Version 2.xx remains under security management practices thereby certified

Revision 1.0 October 19, 2026

ANAB ANSI National Accreditation Board ACCREDITED ISO/IEC 17065 PRODUCT CERTIFICATION BODY #1004

ISASecure Chartered Laboratory:
exida
80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001
ACLASS Cert No: AT-1531

exida®

T-245 V1 R4

Certificate / Certificat

Zertifikat / 合格証

HON 2603046 C001

exida hereby confirms that the

Trend IQ5 System Controllers

Honeywell Technologies Building Automation

Atlanta, Georgia, United States

Conforms to 62443 requirements listed and to requirements shown:

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical security requirements for IACS components

Meeting Requirements for:

ISASecure Component Security Assurance (CSA) 1.0.0 Capability Security Level 2 requirements for embedded devices, referencing errata CSA-102 v2.6

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject under Assessment	Date	Current releases at time of assessment
ISASecure® CSA evaluation	Trend IQ5 System Controllers (IQ5-00-24 and IQ5-28-24)	Oct 5, 2026	v2.30

exida Certification

Tom Mitchell
Evaluating Assessor

Chirag Malkan
Certifying Assessor