

The manufacturer
may use the marks:



ISASecure®
CERTIFIED COMPONENT



Certification Report:

HON 2603046 R001 V1R0

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:

Product certificate remains valid under the following conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number HON 2103121 C001 issued to Honeywell Building Technologies
- Trend IQ5 System Controller Version 2.xx remains under security management practices thereby certified

Revision 1.0 October 19, 2026



ISASecure Chartered Laboratory:
exida

80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001
AClass Cert No: AT-1531



T-245 V1 R4

Certificate / Certificat

Zertifikat / 合格証

HON 2603046 C001

exida hereby confirms that the

Trend IQ5 System Controllers
Honeywell Technologies Building
Automation

Atlanta, Georgia, United States

Conforms to 62443 requirements listed and to requirements shown:

**ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product
development lifecycle requirements**

**ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical
security requirements for IACS components**

Meeting Requirements for:

**ISASecure Component Security Assurance (CSA) 1.0.0
Capability Security Level 2 requirements for embedded
devices, referencing errata CSA-102 v2.6**

The normative documents and issue dates that define this certification are listed
at www.isasecure.org

Assessment	Subject under Assessment	Date	Current releases at time of assessment
ISASecure® CSA evaluation	Trend IQ5 System Controllers (IQ5-00-24 and IQ5-28-24)	Oct 5, 2026	v2.30



Evaluating Assessor

Certifying Assessor