The manufacturer may use the marks:

ISASecure® CERTIFIED COMPONENT

exida CERTIFIED IEC 62443 SL-C 1

Certification Report:
JCI 2507051 R001 V1R0

Application Restrictions:
The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:
Product certificate remains valid under the following conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number JCI 2304032 C001 issued to Johnson Controls International
- The Component described in the table to the right remains under security management practices thereby certified

Revision 1.0 September 23rd, 2026

ANAB ANSI National Accreditation Board ACCREDITED ISO/IEC 17065 PRODUCT CERTIFICATION BODY #1004

ISASecure Chartered Laboratory:
exida
80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001
ACLASS Cert No: AT-1531

exida®

T-171 V1R8

Certificate / Certificat Zertifikat / 合格証

JCI 2507051 C001

exida hereby confirms that the

YE GUI Water-Cooled Centrifugal Chillers

Johnson Controls International PLC
Cork, Ireland

Conforms to 62443 requirements listed and to requirements shown:

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical security requirements for IACS components

Meeting Requirements for:

ISASecure Component Security Assurance (CSA) 1.0.0 Capability Security Level 1 requirements for embedded devices, referencing errata CSA-102 v1.9

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject Model	Subject Type	Current releases at time of assessment
ISASecure® CSA evaluation	YE GUI Water-Cooled Centrifugal Chillers	Centrifugal Chiller Controller	V01

exida Certification

Evaluating Assessor

Chirag Malkan

Certifying Assessor