The manufacturer may use the marks:

Certified Device ISASecure

exida CERTIFIED IEC 62443 SL-C 1

Certification Report:
JCI 2302186 R001 V1R0

Application Restrictions:
The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:
Product certificate remains valid under the following conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number JCI 2302186 C001 issued to Johnson Controls
- YK and YZ Optiview™ Touchscreen V01 remains under security management practices thereby certified

Revision 1.2 October 27, 2026

ANAB
ANSI National Accreditation Board
ACCREDITED
ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#1004

ISASecure Chartered Laboratory:
exida
80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001
ACLASS Cert No: AT-1531

exida®

T-171 V1R7

Certificate / Certificat
Zertifikat / 合格証

JCI 2302186 C001

exida hereby confirms that the

YK and YZ Optiview™ Touchscreen
Johnson Controls
New Freedom, PA, USA

Conforms to 62443 requirements listed and to requirements shown:

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical security requirements for IACS components

Meeting Requirements for:

ISASecure Component Security Assurance (CSA) 1.0.0 Capability Security Level 1 requirements for embedded devices, referencing errata CSA-102 v1.9

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject under Assessment	Date	Current releases at time of assessment
ISASecure® CSA evaluation	YK and YZ Centrifugal Chiller OptiView™ Touchscreen Control Panel	September 30, 2024	V01
ISASecure® CSA certificate update		October 27, 2026	V03, V04

exida Certification

David A Johnson
Evaluating Assessor

Bill Thomson
Certifying Assessor