

The manufacturer
may use the marks:



Certification Report:

HON 2403128 R001 V1R1

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:

Product certificate remains valid under the following conditions:

- The following SDLA certificate remains valid: ISASecure® SDLA certificate number HON 2103121 C001 issued to Honeywell Building Technologies.
- PCD3.M6893, HPCD3.M6893 Version 5.x.x remains under security management practices thereby certified

Revision V1R1 January 31, 2025



ISASecure Chartered Laboratory:
exida

80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001
ACLASS Cert No: AT-1531



T-244 V1 R2

Certificate / Certificat Zertifikat / 合格証

HON 2403128 C001

exida hereby confirms that the

**Saia PCD QronoX (PCD3.M6893)
Control Edge PCD (HPCD.M6893)
Saia-Burgess Controls AG
Givisiez, Switzerland**

Conforms to 62443 requirements listed and to requirements shown:

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical security requirements for IACS components

Meeting Requirements for:

**ISASecure Component Security Assurance (CSA) 1.0.0
Capability Security Level 3 requirements for embedded devices, referencing errata CSA-102 v1.9**

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject under Assessment	Date	Current releases at time of assessment
ISASecure® CSA evaluation	PCD3.M6893 HPCD3.M6893	January 31 st 2025	5.14.8



Evaluating Assessor

Certifying Assessor